



Department of Veterans Affairs

**ELECTRICAL SYSTEMS INSPECTION REPORT
(MANUFACTURED HOME)**

CASE NUMBER

RESPONDENT BURDEN: Public reporting burden for this collection of information is estimated to average 20 minutes per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. If you have comments regarding this burden estimate or any other aspect of this collection of information, call 1-800-827-1000 for mailing information on where to send your comments.

NOTE TO INSPECTOR: All inspections must be completed following installation and set-up.

LOCATION OF MANUFACTURED HOME UNIT

SERIAL NUMBER OF MANUFACTURED HOME UNIT

NAME OF INSPECTOR

NAME AND ADDRESS OF FIRM

TELEPHONE NO.

CERTIFICATION OF ELECTRICAL SYSTEM

- (a) The wiring of each manufactured home shall be subjected to a 1 minute, 900 -volt dielectric strength test (with all switches closed) between life parts (including neutral) and the manufactured home ground. Alternatively, the test may be performed at 1,080 volts for 1 second. This test shall be performed after branch circuits are complete and after fixtures or appliances are installed. Fixtures or appliances which are listed shall not be required to withstand the dielectric strength test.
- (b) Each manufactured home shall be subjected to:
- (1) A continuity test to assure that metallic parts are properly bonded.
 - (2) An operational test to demonstrate that all equipment is connected and in working order.
 - (3) Polarity checks to determine that connections have been properly made.

☐ ALUMINUM WIRING - A visual inspection of all connections to switches, plugs, etc. Loose connections must be tightened.

WIRING SATISFACTORY? ☐ YES ☐ NO

FEDERAL STATUTES PROVIDE SEVERE PENALTIES FOR ANY FRAUD, INTENTIONAL MISREPRESENTATION OR CRIMINAL CONNIVANCE OR CONSPIRACY PURPOSED TO INFLUENCE THE ISSUANCE OF ANY GUARANTY OR INSURANCE OR THE GRANTING OF ANY LOAN BY THE SECRETARY.

I certify that I have carefully inspected the above system in which I have no interest present or prospective and that I have reported herein all observed conditions.

DATE

SIGNATURE OF INSPECTOR

LICENSE NO.